

CITY GUIDELINES FOR REPAIRS IN STREETS  
City of Muscatine, Iowa

1. Dimensions for a Utility Patch:
  - A. Minimum dimensions for a utility patch bounding a joint or pavement edge shall be six (6) feet.
  - B. A patch inside a pavement panel (interior patch) not bounded by a joint or an edge shall have minimum dimensions of four (4) feet.
  - C. All sides of an interior patch shall be at least four (4) feet from a pavement joint.
  - D. Patches should be eight (8) inch thickness minimum.
2. Untreated granular material shall not be placed within eighteen (18) inches of the slab, unless otherwise authorized.
3. Saw cuts shall be a minimum of four (4) inches deep, preferably full depth.
4. Sealcoated streets shall be patched with a minimum of three (3) inches of cold mix asphalt.
5. No frozen material may be placed in the fill.
6. Contractors are required to obtain excavation permits, and to have all utilities located prior to excavation.

